


<b>MH DIMENSIONS/ALLOWANCES</b>				
<b>MH DIAMETER</b>	<b>MIN. WALL THICKNESS</b>	<b>MIN. BASE THICKNESS</b>	<b>MAXIMUM KNOCKOUT SIZE</b>	<b>MINIMUM DISTANCE BETWEEN KNOCKOUTS</b>
48"	4"	6"	36"	8"
54"	4.5"	8"	42"	8"
60"	5"	8"	48"	8"
72"	6"	8"	60"	12"
84"	8"	12"	72"	12"
96"	8"	12"	84"	12"
120"	10"	12"	96"	12"
144"	12"	12"	108"	12"

<b>PIPE ALLOWANCES</b>				
<b>MH DIAMETER</b>	<b>PIPE MATERIAL WITH MAXIMUM INSIDE DIAMETER</b>			
	<b>ALL METAL</b>	<b>CPSSP PP ①</b>	<b>SOLID WALL PVC ②</b>	<b>PROFILE WALL PVC ③</b>
48"	30"	24"	30"	30"
54"	36"	30"	36"	36"
60"	42"	36"	42"	42"
72"	54"	42"	48"	48"
84"	60"	54"	48"	48"
96"	72"	60"	48"	48"
120"	84"	60"	48"	48"
144"	96"	60"	48"	48"

① Polypropylene Pipe (See **WSDOT Standard Specification Section 9-05.24**)

② (See **WSDOT Standard Specification Section 9-05.12(1)**)

③ (See **WSDOT Standard Specification Section 9-05.12(2)**)



**CITY OF EDMONDS**  
PUBLIC WORKS  
DEPARTMENT

**TYPE I MH PIPE  
ALLOWANCES TABLE**

APPROVED BY: R. ENGLISH

REVISION DATE  
SEPTEMBER 2023

STANDARD  
DETAIL  
GU-421B