


NOTES:

1. MINIMUM COVER DEPTHS ASSUME NO VEHICULAR LOADING. DESIGNER TO SPECIFY COVER DEPTH IF VEHICULAR TRAFFIC IS ANTICIPATED. MINIMUM COVER FOR PIPE BELOW PAVEMENT (UNLESS OTHER SUPPORTING DOCUMENTATION IS PROVIDED TO DEMONSTRATE ADEQUATE COVER):
 - 2 FEET FROM BOTTOM OF FLEXIBLE PAVEMENT WEARING COURSE
 - 2 FEET MINIMUM FROM TOP OF RIGID PAVEMENT WEARING COURSE
2. WASHED DRAIN ROCK SHALL CONFORM TO WSDOT SPEC. 9-03.12(5) GRAVEL BACKFILL FOR DRYWELLS. STREAMBED COBBLES SHALL BE 4" COBBLES PER WSDOT SPEC. 9-03.11(2).



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**TYPICAL RAIN GARDEN
PIPED INLET**

APPROVED BY: R. ENGLISH

REVISION DATE
APRIL 2021

STANDARD
DETAIL
SD-603