


NOTES:

1. SADDLE MANHOLE MAY ONLY BE USED WHEN PLACING A NEW MANHOLE OVER AN EXISTING MAIN. SIZE, LOCATION, AND ANGLE MUST BE AS REQUIRED BY PLANS.
2. OPENINGS IN PRECAST UNITS ARE TO BE 4" MINIMUM TO 8" MAXIMUM LARGER THAN THE OUTSIDE DIAMETER OF THE EXISTING AND PROPOSED PIPES.
3. CONSTRUCT BENCH AND INVERT TO ALLOW SMOOTH TRANSITION OF FLOW.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**48" SADDLE CB
FOR 24" AND SMALLER
PIPE**

APPROVED BY: R. ENGLISH

REVISION DATE
OCTOBER 2021

STANDARD
DETAIL
SD-305