


NOTES:

1. CSBC DEPTH SHALL BE A MINIMUM OF 6" THICK.
2. ROADWAY HMA DEPTH SHALL BE A MINIMUM OF 4" THICK.
3. FINAL PAVEMENT JOINTS SHALL BE NEATLY SAW CUT AND UNIFORMLY SEALED PER WSDOT STANDARD SPECIFICATIONS 5-04.3(4)A.
4. UNLESS APPROVED BY THE ENGINEER, THE HMA SHALL BE INSTALLED IN MULTIPLE EQUAL THICKNESS LIFTS NOT EXCEEDING 2".
5. REFER TO EDMONDS COMMUNITY DEVELOPMENT CODE TABLE OF STREET STANDARDS FOR PRIVATE EASEMENT AND PAVEMENT WIDTHS.
6. FIRE DEPARTMENT MAY REQUIRE ACCESS TO BE WIDER THAN REQUIRED IN EDMONDS COMMUNITY DEVELOPMENT CODE IF IT IS DETERMINED FIRE FIGHTING OR RESCUE OPERATIONS ARE HAMPERED.
7. 6" CONCRETE EXTRUDED CURB PER COE STD DETAIL TR-522 OR 18" ASPHALT THICKENED EDGE PER COE STD DETAIL TR-533 REQUIRED.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**PRIVATE STREET
(1-4 LOTS)**

APPROVED BY: R. ENGLISH

REVISION DATE
APRIL 2021

STANDARD
DETAIL
TR-510