


NOTES:

1. CSBC DEPTH SHALL BE A MINIMUM OF 6" THICK.
2. ROADWAY HMA DEPTH SHALL BE A MINIMUM OF 4" THICK.
3. UNLESS APPROVED BY THE ENGINEER, THE HMA SHALL BE INSTALLED IN MULTIPLE EQUAL THICKNESS LIFTS NOT EXCEEDING 2".
4. FINAL PAVEMENT JOINTS SHALL BE NEATLY SAW CUT AND UNIFORMLY SEALED PER WSDOT STANDARD SPECIFICATIONS 5-04.3(4)A.
5. REFER TO EDMONDS COMMUNITY DEVELOPMENT CODE TABLE OF STREET STANDARDS FOR PRIVATE EASEMENT AND PAVEMENT WIDTHS.
6. REFER TO EDMONDS COMMUNITY DEVELOPMENT CODE SIDEWALK STANDARDS FOR SIDEWALK REQUIREMENTS.
7. REFER TO CITY STANDARD DETAIL TR-520 FOR CURB AND GUTTER.
8. REFER TO CITY STANDARD DETAIL TR-531 FOR CONCRETE SIDEWALK.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**PRIVATE STREET
(5-9 LOTS)**

APPROVED BY: R. ENGLISH

REVISION DATE
APRIL 2021

STANDARD
DETAIL
TR-511