


NOTES (BLDGS WITH SETBACKS):

1. THE DCDA AND VAULT SHALL BE LOCATED ON PRIVATE PROPERTY AND ADJACENT TO THE RIGHT-OF-WAY LINE.
2. THE PIV AND FDC SHALL BE LOCATED ON PRIVATE PROPERTY AND SHALL BE NEAR THE DCDA.
3. THE PIV AND FDC SHALL HAVE A 3' MINIMUM CLEARANCE BETWEEN AND AROUND THEM.
4. THE FDC SHALL HAVE A 22° BEND WITH 4" STORZ ADAPTER ON THE END.



CITY OF EDMONDS
PUBLIC WORKS
DEPARTMENT

**FIRE LINE AND 2" DOMESTIC
SERVICE CONNECTIONS (PLAN VIEW)**

ALL ZONES EXCEPT ZERO-SETBACK
BUSINESS/COMMERCIAL

APPROVED BY: **R. ENGLISH**

REVISION DATE
JANUARY 2018

STANDARD
DETAIL

WA-184