

PLANNING & DEVELOPMENT BUILDING DIVISION 121 5th Avenue N P: 425.771.0220 www.edmondswa.gov

SUBMITTAL REQUIREMENTS FOR **TYPE I HOOD SUPPRESSION**

The purpose of this handout is to assist the public in complying with the detailed permit submittal requirements. It is not a complete list of permit or code requirements and should not be used as a substitute for applicable laws and regulations. It is the responsibility of the owner/design professional to review the submittal for completeness. Only complete applications will be accepted by the city for review.

FIRE SUPPRESSION SYSTEM PERMIT SUBMITTAL REQUIREMENTS:

All Type I Hoods are required to have a fire suppression system.

INCLUDE IN THE SUBMITTED PLAN SHEETS:

1)	GENERAL NOTES
	Property address, floor and/or suite number and name of business.
	Designate the use of building or tenant space (i.e., office, retail, medical, etc.) and occupancy group (i.e., B, A3, etc.).
	Specify type of construction of the building (i.e., Type IA, IIB, VA, VB etc.).
2)	WORKING DRAWINGS
	Show equipment and outline of hood overhang with equipment below.
	Show location of piping, manual pull and nozzle locations.
	Class K fire extinguishers are required. Extinguishers must be mounted in an accessible location no more than 30 feet from the appliance(s) served. In large kitchens or multiple cooking stations additional Class K fire extinguisher may be required. The total number and location of Class K fire extinguishers shall be determined by the City Fire Marshal during inspection.
3)	CUT SHEETS
	Provide cut sheets showing nozzles and number used, extinguishing agent and amount, shunt switches, piping, etc. and their UL/FM listings are required.
	NOTE: Make-up air must shut off and the hood exhaust remain operating when suppression system is activated.
PPLY ONLINE:	

AP

Mybuildingpermit.com

Updated on 4.16.24 Page 1 of 1